

**R6-09 CONDITION OF METER**

No meter shall be installed which is mechanically defective, has an incorrect correction factor or has not been tested and adjusted in accordance with Rule R6-26. The capacity of the meter and the index mechanism should be consistent with the gas requirements of the customer.