

**R7-09 DEAD ENDS**

Dead ends in the distribution mains should be avoided so far as possible. If such dead ends exist the utility should provide facilities for flushing if conditions so require.