

**R7-32 PERIODIC TEST**

Meters of a compound, fireline, or turbine type containing a current meter unit in a system supplying clear spring or well water shall be periodically tested as follows. Under average conditions the following intervals between tests shall not be exceeded.

Meter Sizes	Years Between Tests
1 1/2	4
2	4
3	3
4	2
6	1