

10A NCAC 06R .0702 FIRE AND SAFETY REQUIREMENTS

Adult Day Care Homes shall:

- (1) have fire extinguishers of the type recommended by the fire inspector and governed by the North Carolina Fire Prevention Code, centrally located in the kitchen;
- (2) provide automatic station products of combustion type smoke detectors as required by the North Carolina Fire Prevention Code;
- (3) provide listed heat detectors in the attic and basement from the approved list in the North Carolina Fire Prevention Code; and
- (4) provide a fire safety and evacuation plan to be prepared according to requirements of the North Carolina Fire Prevention Code.

*History Note: Authority G.S. 131D-6; 143B-153;
Eff. July 1, 1978;
Amended Eff. July 1, 2007;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. September 6, 2016.*