

**10A NCAC 13F .0308 FIRE EXTINGUISHERS**

- (a) At least one five pound or larger (net charge) A-B-C type fire extinguisher is required for each 2,500 square feet of floor area or fraction thereof.
- (b) One five pound or larger (net charge) A-B-C or CO/2 type is required in the kitchen and, where applicable, in the maintenance shop.

*History Note:* Authority G.S. 131D-2.16; 143B-165;  
Eff. January 1, 1977;  
Readopted Eff. October 31, 1977;  
Amended Eff. July 1, 1990; April 1, 1987; April 1, 1984;  
Recodified from Rule .0306 Eff. July 1, 2004;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. March 6, 2018.