

10A NCAC 13F .0310 ELECTRICAL OUTLETS

All adult care home electrical outlets in wet locations at sinks, bathrooms and outside of building shall have ground fault interrupters.

History Note: Authority G.S. 131D-2.16; 143B-165;
Eff. January 1, 1977;
Readopted Eff. October 31, 1977;
Amended Eff. April 1, 1984;
Recodified from Rule .0308 Eff. July 1, 2004;
Temporary Amendment July 1, 2004;
Amended Eff. July 1, 2005;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. March 6, 2018.