

10A NCAC 14J .1524 SHOWER STALLS

- (a) The dimensions of showers shall be at least 30 inches x 30 inches x 7 feet.
- (b) Shower stalls shall be constructed of either concrete, masonry, at least 1/8 inch galvanized steel plate, heavy gauge aluminum plate, or heavy gauge stainless steel according to approved plans and specifications.
- (c) The shower stall shall be attached to the wall of the dayroom.
- (d) The floor of the shower stall shall be approximately eight inches above floor level and it shall slope to the floor shower drain.
- (e) A curb that is approximately four inches above the shower floor shall extend across the front of the shower stall. The top of the curb shall have a smooth edge.
- (f) The shower head and the push-button valve assembly shall be vandal proof, and the metering valve and temperature balance mechanism shall be concealed.

History Note: Authority G.S. 153A-220; 153A-221;
Eff. June 1, 1990;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. January 5, 2016.