

**10A NCAC 14J .1222 STANDARDS FOR SINGLE SEGREGATION CELLS**

Each single cell used for segregation shall have:

- (1) a shower or access to a shower;
- (2) a telephone jack or other telephone arrangement;
- (3) a food pass;
- (4) a minimum floor space of 70 square feet, a minimum floor dimension of 7 feet, a toilet, a sink, a drinking fountain and a security mirror.

*History Note: Authority G.S. 153A-221;  
Eff. June 1, 1990;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. January 5, 2016.*