

**10A NCAC 14J .1506 MULTIPLE ROOM REQUIREMENTS**

- (a) The capacity of multi-room units shall not exceed four inmates.
- (b) The minimum room area shall be nine feet by seven feet by eight feet.
- (c) The room shall have a combination lavatory, commode and drinking fountain (see Rule .1534 of this Section).
- (d) The room shall have hot and cold water unless it is contained in a confinement unit with a dayroom that has hot and cold water.
- (e) Except for local lockups, each room shall have a shower with hot and cold water.
- (f) An approved mirror shall be installed (see Rule .1521 of this Section).
- (g) No more than four approved stationary steel bunks shall be installed within each room.
- (h) Natural light shall be admitted to the room in compliance with the North Carolina State Building Code.

*History Note:* Authority G.S. 153A-220; 153A-221;  
Eff. June 1, 1990;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. January 5, 2016.