

10A NCAC 14J .1607 GENERAL REQUIREMENTS

In addition to the rules in this Section, the minimum secure unit shall be designed to:

- (1) allow access for emergency equipment (e.g., fire hoses, stretchers) provided at appropriate entrances;
- (2) have auxiliary power and emergency lighting available;
- (3) have vehicle parking for both public and facility staff and be so designed to prevent unauthorized persons from entering the security perimeter.

History Note: Authority G.S. 153A-230.3; 153A-230.4;
Eff. June 1, 1990;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. January 5, 2016.