

**10A NCAC 70I .0911      CORRIDORS**

- (a) Corridors shall be a minimum clear width of three feet.
- (b) Corridors shall be lighted with night lights providing one foot-candle of light at the floor.
- (c) Corridors shall be free of all equipment and other obstructions.

*History Note:*      *Authority G.S. 131D-10.5; 143B-153;*  
*Eff. October 1, 2008;*  
*Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. April 5,*  
*2016.*