

13 NCAC 13 .0209 INSTALLERS TO NOTIFY CHIEF INSPECTOR

Any company or individual installing boilers or pressure vessels subject to inspection in accordance with this Chapter shall notify the Chief Inspector and request a certificate inspection not less than 10 working days prior to placing equipment in operation. Any company or individual wishing to install used boilers or pressure vessels that are subject to this Chapter shall request permission using the Used Boiler/Pressure Vessel Installation Request Form found on the Boiler Safety Bureau website. Equipment shall not be operated, other than for testing, prior to an inspection being conducted that finds the boiler or pressure vessel to be in compliance with this Chapter.

*History Note: Authority G.S. 95-69.11; 95-69.14;
 Eff. May 29, 1981;
 Amended Eff. July 1, 2011; July 1, 2006; January 1, 1995;
 Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 22,
 2018;
 Amended Eff. January 1, 2020.*