

13 NCAC 13 .0417 SUPPORTS

Each boiler and pressure vessel shall be supported by masonry or structural supports of sufficient strength and rigidity to safely support the boiler or pressure vessel and its contents and distribute the weight contained thereon. There shall be no excessive vibration in the boiler, pressure vessel, or connected piping or fittings.

*History Note: Authority G.S. 95-69.11; 95-69.14;
 Eff. May 29, 1981;
 Recodified from 13 NCAC 13 .0408 Eff. January 1, 1995;
 Amended Eff. January 1, 2009;
 Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 22,
 2018.*