

13 NCAC 13 .0418 VENTING OF NON-PRESSURIZED CONDENSATE RECEIVERS

Two means of venting shall be provided on any condensate receiver tank equipped with an internal float. The tank shall have two separate connections, one to be used as a vent and one as an overflow, and shall be so piped.

*History Note: Authority G.S. 95-69.11; 95-69.14;
Eff. May 29, 1981;
Recodified from 13 NCAC 13 .0412 Eff. January 1, 1995;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 22, 2018.*