

**13 NCAC 13 .0418 VENTING OF NON-PRESSURIZED CONDENSATE RECEIVERS**

Two means of venting shall be provided on any condensate receiver tank equipped with an internal float. The tank shall have two separate connections, one to be used as a vent and one as an overflow, and shall be so piped.

*History Note: Authority G.S. 95-69.11; 95-69.14;  
Eff. May 29, 1981;  
Recodified from 13 NCAC 13 .0412 Eff. January 1, 1995;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 22, 2018.*