

**13 NCAC 15 .0309            LIMITATIONS ON WHEELCHAIR LIFTS**

No inclined or vertical wheelchair lift shall be installed between any two floors already being served by an elevator.

*History Note:    Authority G.S. 95-110.5;  
                      Eff. August 1, 1987;  
                      Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. January 5, 2016.*