02 NCAC 09L .2003 PROHIBITION OF CONNECTION TO A PUBLIC WATER SYSTEM

(a) An irrigation system used for pesticide application shall not be connected to a public water system.

(b) The water from a public water system shall be discharged into a reservoir tank.

(c) There shall be a physical break (air gap) between the outlet end of the fill pipe and the top or overflow rim of the reservoir tank of at least twice the inside diameter of the fill pipe.

History Note: *Authority G.S. 143-463; 143-466;*
Eff. January 1, 1987;
Readopted Eff. August 1, 2020.