

11 NCAC 05A .0909 RESPONSE TO STRUCTURE FIRES

- (a) Each fire department shall ensure the response of at least four of its eligible firefighters and one engine to all structure fires. The fire chief may be one of the four responding members.
- (b) The fire department responding to a structure fire shall have a plan to provide a minimum flow of 200 GPM for 20 minutes within five minutes of the first arriving engine.

History Note: *Authority G.S. 58-2-40; 58-36-10; 58-40-25;*
Eff. January 1, 2018.