

13 NCAC 15 .0309 LIMITATIONS ON WHEELCHAIR LIFTS

No inclined or vertical wheelchair lift shall be installed between any two floors already being served by an elevator.

*History Note: Authority G.S. 95-110.5;
 Eff. August 1, 1987;
 Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. January 5, 2016.*