

**15A NCAC 18A .1311 LIGHTING AND VENTILATION**

- (a) The areas interior to an institution's building or buildings shall be equipped with at least 10 foot candles of light at 30 inches above the floor.
- (b) Ventilation equipment shall be kept clean and in good repair.
- (c) Ambient indoor air temperatures shall be maintained at or below 85 degrees Fahrenheit.

*History Note: Authority G.S. 130A-4; 130A-29; 130A-235;  
Eff. February 1, 1976;  
Readopted Eff. December 5, 1977;  
Amended Eff. March 1, 2003 (see S.L. 2002-160); September 1, 1990; July 1, 1986; October 1,  
1985;  
Readopted Eff. December 1, 2022.*