

15A NCAC 18A .1727 CONTINUOUS DISINFECTION

- (a) A supply which is in violation of Rule .1725(c)(1) of this Section may be used provided that the supply shall be continuously disinfected and a chlorine residual is maintained of at least 0.2 mg/l by use of equipment designed for this purpose. An operator shall be required for a water supply using continuous disinfection. The operator shall hold a valid certificate issued by the N.C. Water Treatment Facility Operators Certification Board.
- (b) The owner, operator, or permittee shall provide to the Department a statement from the operator that a supply using continuous disinfection has a minimum chlorine residual of 0.2 mg/l and a chlorine contact time of at least 20 minutes.
- (c) A disinfection device shall not be used to comply with a violation of Rule .1725 (b)(1) of this Section.

*History Note: Authority G.S. 95-225; 130A-5(3); 130A-228; 130A-230; 130A-235; 130A-236; 130A-248; 130A-257;
Eff. July 1, 1993;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 20, 2019.*