

15A NCAC 18A .2526 DRESSING AND SANITARY FACILITIES

- (a) Dressing and sanitary facilities shall be provided at all pools, except for pools at hotels, motels, condominiums, and apartments where pool use is restricted to residents or guests. At hotels, motels, condominiums and apartments where the farthest unit is more than 300 feet from the pool, as measured along walkways provided for access by residents or guests to the pool area, a toilet and lavatory shall be provided. All public swimming pools shall post a sign visible upon entering the pool enclosure directing pool users to shower before entering the pool.
- (b) Partitions shall be of material, not subject to damage by water and shall be designed so that a waterway is provided between partitions and floor to permit thorough cleaning of the walls and floor areas with hoses and brooms.
- (c) Dressing facility floors shall be continuous throughout the areas. Floors shall have a slip-resistant surface that shall be smooth, to insure complete cleaning. Floor drains shall be provided, and floors shall be sloped not less than ¼ inch per foot toward the drains to insure positive drainage.
- (d) Hose bibs shall be provided such that all parts of the dressing facility interior can be reached with a 50 foot hose.
- (e) The minimum number of fixtures required in dressing and sanitary facilities shall be based upon the maximum bather load.
- (f) One water closet, one lavatory, and one urinal shall be provided for the first 100 male users. One additional water closet, lavatory, and urinal shall be provided for each additional 200 male users up to a total of 500 users. Where user load exceeds 500 male users, two additional water closets or urinals and one lavatory shall be provided for each additional 250 male users. Where the maximum bather load includes less than 50 male users, one water closet and one lavatory will be sufficient.
- (g) Two water closets and two lavatories shall be provided for the first 100 female users. One additional water closet and lavatory shall be provided for each additional 100 female users up to a total of 500 users. Where user load exceeds 500 female users, two additional water closets and one lavatory shall be provided for each additional 250 female users. Where the maximum bather load includes less than 50 female users, one water closet and one lavatory will be sufficient.
- (h) Showers shall be provided in the proportion of one for each 200 persons at the time of maximum bather load.
- (i) The water heater shall be inaccessible to users. The system shall be designed such that water temperature at the shower heads and lavatories cannot exceed 110° Fahrenheit.
- (j) Soap dispensers with either liquid or powdered soap shall be provided at each lavatory or required shower. The dispenser shall be of all metal or plastic type, with no glass permitted in these units.
- (k) If mirrors are provided, they shall be of shatterproof materials.
- (l) Toilet paper holders with toilet paper shall be provided at each water closet.
- (m) Dressing and sanitary facilities shall be kept clean and in good repair.

*History Note: Authority G.S. 130A-282;
Eff. May 1, 1991;
Amended Eff. February 1, 2004; April 1, 1999; January 1, 1996; July 1, 1992;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. July 20, 2019.*