

15A NCAC 18C .0603 INTAKE CONDUITS

The pipes, tunnels, or flumes used for intake conduits shall be designed to conduct water at self-cleaning velocities of at least two feet per second. A screen, accessible for cleaning, shall be provided to protect the pumps.

*History Note: Authority G.S. 130A-315; 130A-317; P.L. 93-523;
Eff. January 1, 1977;
Readopted Eff. December 5, 1977;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.*