

## **SECTION .0800 - HYDROPNEUMATIC STORAGE TANKS RULES**

.0801 - .0805 of Title 15A Subchapter 18C of the North Carolina Administrative Code (T15A.18C .0801 - .0805); has been transferred and recodified from Rules .2001 - .2005 Title 10 Subchapter 10D of the North Carolina Administrative Code (T10.10D .2001 - .2005), effective April 4, 1990.

### **15A NCAC 18C .0801 CAPACITIES: DETERMINING MINIMUM EFFECTIVE VOLUME**

The minimum effective volume of pressure tanks, in gallons, shall equal the peak demand, in gallons per minute, minus the pumping capacity (gpm), multiplied by 20.

*History Note:* Authority G.S. 130A-315; 130A-317; P.L. 93-523;  
Eff. January 1, 1977;  
Readopted Eff. December 5, 1977;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.