

15A NCAC 18C .0902 NUMBER OF RESIDENCES ON A WATER MAIN

(a) No more than 20, or the equivalent of 20 residences shall be connected to a two-inch diameter water line, unless the main is looped or otherwise supplied from two connections with mains of adequate capacities.

(b) A looped two-inch main shall serve no more than 40 residences, or the equivalent water demand of 40 residences. A two-inch diameter main shall not exceed 1000 feet in length.

*History Note: Authority G.S. 130A-315; 130A-317; P.L. 93-523;
Eff. January 1, 1977;
Readopted Eff. December 5, 1977;
Amended Eff. January 1, 1978;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.*