

**15A NCAC 18C .0903 DEAD-END WATER MAINS**

Where installation of dead-end water mains cannot be avoided, a hydrant or a valve of adequate size for flushing shall be installed at the terminal end of the line. The flush valves shall have an above-ground discharge and shall be protected from contamination.

*History Note: Authority G.S. 130A-315; 130A-317; P.L. 93-523;  
Eff. January 1, 1977;  
Readopted Eff. December 5, 1977;  
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.*