

15A NCAC 18C .0905 TESTING NEW WATER MAINS

New water mains shall be tested for leakage and any necessary repairs and re-testing shall be accomplished as specified in AWWA standards.

*History Note: Authority G.S. 130A-315; 130A-317; P.L. 93-523;
Eff. January 1, 1977;
Readopted Eff. December 5, 1977;
Pursuant to G.S. 150B-21.3A, rule is necessary without substantive public interest Eff. November 23, 2015.*