

**15A NCAC 18C .1002    DISINFECTION OF WELLS**

(a) After construction, servicing, maintenance, or any other activity or event that might lead to contamination of the water, wells shall be disinfected in accordance with ANSI/AWWA C654-13, "Disinfection of Wells." Copies may be obtained for public inspection as set forth in Rule .0503 of this Subchapter.

(b) After disinfection, wells shall not be placed into service until bacteriological test results of representative water samples analyzed by a certified laboratory are found to be satisfactory.

(c) Records demonstrating compliance with ANSI/AWWA Standard C654-13 shall be available for three years for inspection by the Department.

*History Note:    Authority G.S. 130A-315; 130A-317; P.L. 93-523;  
Eff. January 1, 1977;  
Readopted Eff. December 5, 1977;  
Amended Eff. July 1, 1994;  
Readopted Eff. July 1, 2019.*