

15A NCAC 18C .1529 POINT-OF-ENTRY, BOTTLED WATER, AND OTHER TREATMENT DEVICES

(a) The provisions of 40 C.F.R. 141 Subpart J – Use of Non-Centralized Treatment Devices are incorporated by reference, including subsequent amendments and editions. Copies may be obtained as set forth in Rule .0102(b) of this Subchapter.

(b) Public water systems shall not use bottled water or point-of-use devices to achieve compliance with a maximum contaminant level. Bottled water or point-of-use devices may be used on a temporary basis until compliance with the maximum contaminant level is achieved.

*History Note: Authority G.S. 130A-315; P.L. 93-523; 40 C.F.R. 141;
Eff. June 1, 1988;
Transferred and Recodified from 10 NCAC 10D .1641 Eff. April 4, 1990;
Amended Eff. September 1, 1990;
Readopted Eff. July 1, 2019.*