

15A NCAC 18E .1307 WASTEWATER SYSTEM ABANDONMENT

If a wastewater system is abandoned or is otherwise no longer in use, the tanks shall:

- (1) have the contents removed by a septage management firm permitted in accordance with G.S. 130A-291.1;
- (2) be removed, collapsed, or otherwise rendered unable to retain liquid, and backfilled; and
- (3) have the electrical components de-energized and above ground components removed.

History Note: Authority G.S. 130A-335;
Eff. January 1, 2024.